

Application of San Diego Gas & Electric Company
(U-902-E) for Adoption of an Advanced Metering
Infrastructure Deployment Scenario and Associated Cost
Recovery and Rate Design.

Application 05-03-015
Exhibit No.: _____

CHAPTER 11

**COMMUNICATION SYSTEM, ~~ELECTRIC METERS~~ AND
PROGRAMMABLE CONTROLLABLE THERMOSTATS**

Deleted: AND

JULY 14, 2006 AMENDMENT

**Prepared Supplemental, Consolidating,
Superseding and Replacement Testimony
Of**

PAUL PRUSCHKI

SAN DIEGO GAS & ELECTRIC COMPANY

**BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF CALIFORNIA**

July 14, 2006

*Material changes to this testimony can be found on pages: 1, 2, 3, 4, 5, 6, 9, 10, 11, 12
and 13,*

TABLE OF CONTENTS

I.	INTRODUCTION.....	1
II.	BACKGROUND	2
III.	BASE ASSUMPTIONS	2
	A. Communication System	2
	B. Electric Meters	3
	<u>C. Programmable Controllable Thermostats</u>	<u>3</u>
IV.	AMI TECHNOLOGY	34
V.	SUMMARY OF COSTS & BENEFITS	7
	A. Communication System	7
	B. Electric Meter.....	8
	<u>C. Programmable Controllable Thermostats</u>	<u>9</u>
	<u>D. Operation and Maintenance Costs (O&M)</u>	<u>9</u> <u>10</u>
	<u>E. System Operation Benefits</u>	<u>11</u>
VI.	AMI costs impacts by functional area- by capital, by O&M	12
VII.	AMI BENEFITS IMPACTS BY FUNCTIONAL AREA- BY CAPITAL, BY O&M	13
VIII.	AMI RISK MITIGATION.....	13
IX.	CONCLUSION	14
X.	QUALIFICATIONS OF PAUL PRUSCHKI.....	15

1 respondents. As such, vendors did not provide product or pricing information for
2 that section. Once SDG&E decided to include PCTs, SDG&E contacted selected
3 AMI vendors to determine their PCT product offerings and requested preliminary
4 PCT pricing information. The PCTs that the vendors proposed are capable of
5 two-way communications through the AMI communications network. The
6 responses, along with prior experience from SDG&E's Smart Thermostat
7 Program, were used to identify the costs included in this amended testimony.

8 PCTs are expected to be deployed between 2009 and 2013 at approximately
9 16,600 small and medium commercial and industrial (C&I) customer premises
10 with a peak demand less than 200 kW. Because these premises typically have
11 multiple PCTs per location, the actual PCT total will be approximately 57,000.
12 Title 24 standards for PCTs are still in development and this business case does
13 not propose a solution, but rather makes the assumption that the existing AMI
14 communication network can be used for PCT communications.

15
16 **IV. AMI TECHNOLOGY**

17 The RFP process established that multiple technologies are available from the
18 marketplace that can satisfy SDG&E's functional requirements. The technologies can be
19 disaggregated at a high level into two separate categories: powerline carrier (PLC), and
20 radio frequency (RF), often referred to as wireless. RF can be further broken down into
21 two separate categories: licensed (the utility owns or leases the RF spectrum) and
22 unlicensed (the utility does not own and shares the RF spectrum with other users).
23 Powerline carrier, as the name suggests, communicates over the utilities existing
24 powerlines. RF, on the other hand, communicates wirelessly over the air. It is important
25 to note that the technologies referred to here apply to communication to/from an endpoint
26 device (the meter, PCT, etc.) and a higher-level collection device. SDG&E refers to
27 these components of the system as the local area network (LAN). As these technologies
28 relate to AMI, there are pros and cons that depend on the specific application. These
29 applications can relate to meter density per square mile or substation, and rural versus
30 urban/suburban environments (morphology). An important point to note is that gas
31 meters do not have available power, and for safety and maintenance reasons SDG&E will

1 In order to mitigate what we see as a risk associated with fielding large
2 numbers of new, solid state meters for our customers, SDG&E assumed an
3 additional 0.5% risk.¹ To address this, SDG&E requested in the RFP that the
4 vendors absorb this additional risk. The RFP responses failed to fully mitigate
5 this risk.

6 SDG&E also required vendors to provide at least two separate meter vendors
7 in their RFP response. This resulted in a marginal increase in meter cost, but
8 should aid in mitigating meter supply issues and reduce exposure to large-scale
9 meter failures (i.e.: flaws found with a particular lot or family of meters will be
10 somewhat minimized due to this ‘diversification’ in the meter population).

11 **C. Programmable Controllable Thermostats (PCTs)**

12 The cost of a PCT includes the AMI communication module that is embedded
13 in the PCT and the cost of a new PCT. As with the communication system
14 devices, the PCT cost estimates are based on actual pricing data received from
15 select vendors. Prior experience from SDG&E’s Smart Thermostat Program was
16 used to determine installation costs and failure rates. This cost data, together with
17 the actual quantities of PCTs, was used to develop the PCT costs. Also
18 incorporated into these costs are replacement PCTs due to failures. SDG&E’s
19 Smart Thermostat Program demonstrated an annual failure rate of 2.0%. Based
20 on the California Energy Commission’s (CEC) Public Interest Energy Research’s
21 (PIER) draft report on “Demand Responsive Control of Air Conditioning via
22 Programmable Controllable Thermostats (PCTs)”, dated February 14, 2006,
23 SDG&E’s business case costs were modeled with an expected life of 15 years.
24 The PCTs are to be deployed between 2009 and 2013. Therefore, costs for a ‘re-
25 deployment’ of PCTs is included in the 2024 – 2028 period (excluding those
26 PCTs replaced due to failure during the intervening years). Replacement of failed
27 PCTs is included in the period 2029-2038.

¹ Based on current experience with poly-phase solid-state meters without AMI communications, SDG&E used an overall failure rate of 1.0% for all solid-state meters with AMI functionality.

Deleted: was used

1 Installation costs were used based on SDG&E's Smart Thermostat Program.
2 This amounted to \$75 for the first PCT at a customer location, and \$25 for each
3 additional PCT at the same location.

4 **D. Operation and Maintenance Costs (O&M)**

5 The following are the O&M costs based on a full AMI deployment.

6 **1. Communication System Costs**

7 SDG&E estimated the following costs:

8 **a.** Incremental costs to existing O&M due to AMI functionality in the
9 meter and the communications infrastructure (labor, tools, equipment
10 vehicles).

11 **b.** Attachment costs for collection devices (e.g., rent or lease charges by
12 cities or other third parties not owned by utility).

13 **c.** Dispatching and O&M of field employees associated with LAN/WAN
14 and infrastructure equipment.

15 **d.** Backhaul cost of public network connections (WAN Common Carrier
16 costs - Verizon, AT&T, etc.). Backhaul from collection devices to the
17 utility's back office system is anticipated to be via a public network. This
18 will also require frame relay circuits between the public carrier and
19 SDG&E.

20 **e.** Electric power consumed by LAN/WAN equipment was based on data
21 supplied by the vendors on typical usage for collection devices.

22 **2. Electric Meter Costs**

23 **a. Meter Engineering Labor:**

24 Due to the large volume of new solid state meters that will be
25 deployed, additional SDG&E meter engineering resources will be
26 required. These employees will support field metering personnel and
27 communications support staff in conducting product failure analysis,
28 evaluation and testing of firmware upgrades, coordinate programming
29 changes and follow up with the vendors to ensure product support for the
30 life of the meters.

1
 2
 3
 4
 5
 6
 7
 8
 9
 10
 11
 12
 13
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23
 24
 25
 26
 27
 28
 29
 30

b. Battery Replacement Costs:

SDG&E anticipates that the poly-phase meters will have backup batteries within the meter to maintain time when power outages occur depending upon the technology chosen. These batteries are expected to have a 10-15 year life. Costs for the replacement batteries were derived from the current costs for backup batteries in commercial meters and were replaced in the tenth year after installation. Costs were included for all installed poly-phase commercial meters (growth and deployment).

c. Power Consumption:

Any AMI solution installed under the meter cover will result in increased un-metered power consumption and thus additional load on the electric utility grid. SDG&E completed an analysis of measurements from devices currently under test and noted a continuous non-transmitting power consumption increase. Vendors also provided the watt loss power consumption increase for the communication solution in response to questions raised during the RFP process. When combined with the differential cost of watt loss between solid-state meters and mechanical meters and the number of metering devices deployed, a total cost for additional energy consumption is calculated and also included in the costs covered in this chapter.

3. Programmable Controllable Thermostat (PCT) Costs

- a. The PCTs will use the AMI communications network and will not add any incremental communications costs.

E. System Operation Benefits

1. Growth Meter Displacement

Once the initial deployment of AMI begins in mid 2008, new solid state AMI-enabled meters will be installed for all future customer growth. Therefore, SDG&E will avoid the capital expenditures associated with the purchase of electromechanical meters for new customer growth. Costs savings are included based upon the type of meter that SDG&E expects to

1 maintenance of the network will transfer to SDG&E. Viable RFP respondents included
2 these performance requirements in their RFP bids.

3 **IX. CONCLUSION**

4 My testimony has discussed both the costs and benefits related to deploying an
5 AMI communication system. The most significant contribution to the overall project
6 costs comes from the purchase and installation of solid state meters with embedded AMI
7 modules and associated network communications infrastructure. Based on the ‘not to
8 exceed’ costs included in this chapter we are confident that a system can be procured that
9 will provide the functionality described in Mr. Reguly’s testimony (Chapter 8) and
10 therefore enable the benefits described throughout other chapters in [SDG&E’s AMI](#)

Deleted: this business case

11 [filing](#).

12 My testimony also discussed at a high level the various technologies available for
13 AMI. Through the RFP process, SDG&E determined that there were technologies
14 available from the marketplace that could provide the functionality, and therefore the
15 benefits, necessary to meet our requirements. SDG&E will be field-testing various
16 technologies to determine which technologies best meet the functional requirements
17 based on meter density and morphology.

18 This concludes my testimony.

1 **X. QUALIFICATIONS OF PAUL PRUSCHKI**

2 My name is Paul Pruschki and I am employed by San Diego Gas & Electric
3 Company (SDG&E). My business address is 8326 Century Park Court, CP62C, San
4 Diego, CA 92123.

5 My present position is Measurement Data Communications Manager in the
6 Network Engineering & Operations Department of SDG&E. I have been employed by
7 SDG&E since 2003. Previous positions relevant to my testimony include Technical
8 Project Manager (2000-2003), RF Manager (1997-1999) and RF Engineer (1992-1997).

9 I received a B.S. in Electrical Engineering from Rensselaer Polytechnic Institute.

10 I have not previously testified before the California Public Utilities Commission.

