

Proceeding No.: I.08-11-007  
Exhibit No.: \_\_\_\_\_  
Witness: Paul Alvarado

**DIRECT TESTIMONY OF**  
**PAUL ALVARADO**  
**SAN DIEGO GAS & ELECTRIC COMPANY**

**BEFORE THE PUBLIC UTILITIES COMMISSION  
OF THE STATE OF CALIFORNIA  
May 18, 2009**





1 Order 95. It is SDG&E's custom and practice to design so as to meet or even exceed General  
2 Order 95 requirements.

3 Q: Can you give us some background regarding the subject span?

4 A: Yes. The Guejito Circuit, which includes poles 196394 and 196387, was originally  
5 installed in July 1927. At that time, pole numbers 196394 and 196387 had pole numbers 14286  
6 and 14288, respectively. To avoid confusion, I will use the current pole numbers.

7 Q: Was the span between poles 196394 and 196387 modified or reconstructed at any time  
8 after original installation and before October 22, 2007?

9 A: Yes. Based on my review of the construction records, it appears that in 1956, an anchor  
10 was installed at pole 196394, and another phase conductor was added to that pole in 1957. In  
11 1966, pole 196394 was replaced. In 1974, due to work being done to State Highway 78, portions  
12 of the Guejito Circuit were relocated, and pole 196394 was moved and replaced at that time.  
13 Subsequently, in the late 1970s or early 1980s, pole 14287 -- which was originally between poles  
14 196394 and 196387 -- was removed from service due to its location in a natural drainage area,  
15 and the span between poles 196394 and 196387 was reconfigured. Also, our records show that  
16 the original span conductors installed in 1927 were #4 solid copper. The conductors were  
17 replaced with #4/3 "bare strand" copper, either in connection with the work done in 1974 or the  
18 reconfiguration of the span in the late 1970s or early 1980s. In 1988, pole 196387 was replaced.  
19 In October 2005, avian protection was installed on the upper level primary conductors attached  
20 to pole 196394 (these are not the span conductors between poles 196394 and 196387). It is my  
21 belief that this work was and is in compliance with General Order 95.

22 Q: The report regarding the Guejito Fire that SDG&E submitted to the CPUC in connection  
23 with its January 8, 2009 response to data requests indicated that the conductors in this span were  
24 also replaced in 1988. Is that correct?

25 A: Based on my review of the relevant construction work orders, it does not appear to me  
26 that the conductors were replaced in 1988. I believe the last time the conductors were replaced  
27 prior to October 22, 2007 was in connection with the work done in 1974 or the work done in the  
28 late 1970s or early 1980s.

1 Q: Based on your review of these work orders, did SDG&E do any construction work on the  
2 span between poles 196394 and 196387 after Cox installed its facilities in 2001 and before  
3 October 22, 2007?

4 A: No.

5 Q: Can you visually describe the span between poles 196394 and 196387 – for example,  
6 what are the pole top configurations?

7 A: I have attached photographs of the pole top configurations to my testimony (Exhibits 1  
8 and 2) and can also describe them. Pole 196387 is built to a three-wire delta configuration on a  
9 standard 10-foot distribution cross-arm with pin and insulator construction. This means that the  
10 center phase conductor is mounted at the top of the pole, centered between the two outer phase  
11 conductors, which are on the cross-arm. In this delta configuration, the two outer phase  
12 conductors are attached approximately seven feet below the center phase conductor. This  
13 construction affords the maximum horizontal phase spacing to keep the conductors from  
14 contacting each other. Pole 196394 is built to a three-wire horizontal dead-end configuration on  
15 standard 10-foot distribution double dead-end cross-arms. The center phase conductor is  
16 attached to the cross-arm through-bolt and centered on the pole. The two outer phase conductors  
17 are attached to the cross-arm in the standard position for a dead-end cross-arm. The three  
18 conductors are near equal distance apart horizontally. At pole 196394, the closest horizontal  
19 distance between phase conductors is 4.67 feet (or 56 inches). At pole 196387, the closest  
20 horizontal distance between phase conductors is 5.09 feet (or 61 inches). The horizontal  
21 clearance between conductors at both poles actually exceeds the General Order 95 minimum  
22 (which is 52 inches).

23 Q: How long is the span between poles 196394 and 196387?

24 A: 872.5 feet, according to the survey done by Nolte & Associates.

25 Q: What type of conductors was in place on October 22, 2007?

26 A: American Wire Gauge (AWG) #4/3 “bare strand” copper, composed of three strands.

27 Q: To your knowledge, how was the span between poles 196394 and 196387 designed?  
28

1 A: It is SDG&E's custom and practice to design its overhead distribution systems in  
2 accordance with General Order 95 and its internal overhead construction standards. SDG&E  
3 considers a number of factors in the design process, including conductor size and type, wind  
4 speed, sag and tension calculations and span length. Longer cross-arms and varying  
5 configurations, such as a delta configuration, are often used to increase the phase to phase  
6 clearances to ensure compliance. SDG&E uses standard sag and tension tables to ensure  
7 adequate clearance above the ground and above foreign utilities. SDG&E also utilizes a  
8 computer program called "Sag-10," which generates sag tables based on inputted factors,  
9 including conductor size and type, temperature, design tension, ruling span, and longest span.  
10 This information is used to ensure that the lines comply with General Order 95 and to perform  
11 additional calculations to determine phase spacing. Although we have not been able to find  
12 design and construction documents relating to the reconfiguration of the lines that dates back to  
13 the late 1970s or early 1980s when pole 14287 was removed, it is my understanding that when  
14 pole 14287 was removed a transit was used as part of the work, which would ensure that the  
15 resulting longer span remained in compliance with General Order 95.

16 Q: Do you have any reason to believe that the subject span was not constructed to comply  
17 with General Order 95 when it was reconfigured in the late 1970s or early 1980s?

18 A: No, and the fact that a transit was being used when the work was done indicates to me  
19 that the lines were constructed per SDG&E's design.

20 Q: Would an 872.5-foot span, such as the subject span, be designed using different methods  
21 than those used for other spans?

22 A: No, but for longer spans, the designers would run a custom sag and tension calculation,  
23 using the same factors described above. If the subject span was reconfigured before the  
24 company had "Sag-10" or the prior program Alcoa Sag and Tension (which was being used  
25 when I joined the Distribution Engineering Group in 1985), hand calculations would have been  
26 done to determine sag. It is my understanding that the sag would then have been overlaid on the  
27 profile of the topography for the area to ensure sufficient ground clearance and that pole heights  
28 and configurations would also have been determined using the sag information.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

Q: Does SDG&E have any other spans over 850 feet in length in its electric system?

A: Yes. According to SDG&E's records, there are approximately 250 overhead distribution spans in the system that exceed 850 feet.

Q: Is there a wind speed for which the subject span was designed to withstand?

A: The span was designed to light loading criteria pursuant to General Order 95 and SDG&E's internal standards. Light loading takes into account a wind pressure of 8 lbs per square foot of projected area on cylindrical surfaces, which equates to a wind speed of 56 mph.

## QUALIFICATIONS

1  
2 My name is Paul Alvarado. My business address is 8316 Century Park Court, San Diego,  
3 California, 92123. I have been employed by San Diego Gas & Electric Company (“SDG&E”)  
4 for over 36 years. My current title is Technical Advisor and I work in the Electric Distribution  
5 Engineering Department. My responsibilities are to create and maintain the Distribution  
6 Overhead Construction Standards to ensure compliance with the CPUC General Order 95 Rules,  
7 create and maintain the Assembly Units and Macro Units in the Distribution Planning and  
8 Scheduling System, and evaluate and approve some of the distribution equipment, including  
9 Overhead Switches, Fused Cutouts, Pole Line Hardware, Street Lighting Equipment, and Avian  
10 Protection. From my hire date in October 1972 until September 1981, I worked as a power plant  
11 operator at the South Bay Power Plant in Chula Vista, California. As an operator, I qualified for  
12 and worked as an Auxiliary Engineer, Assistant Control Operator, Control Operator, Relief Shift  
13 Supervisor, and Fuel System Transfer Operator. In addition, I trained and certified power plant  
14 operators for a period of one year. From September 1981 until May 1983, I worked as an  
15 Engineering Assistant at the Silver Gate Power Plant in San Diego, and from May 1983 until  
16 October 1983, I worked as a Work Order Planner in the Gas Turbine Maintenance Department at  
17 the Station B Power Plant in San Diego. While employed at SDG&E, I earned my Associate in  
18 Science degree in Management from Southwestern Community College in June 1985. Prior to  
19 my employment at SDG&E, I served in the United States Navy as a Boiler Technician from  
20 October 1968 to October 1972. I attended and graduated from Basic Propulsion Engineering  
21 School and Boilerman Class A School at Great Lakes Naval Station, North Chicago, IL. While  
22 in the Navy, I earned the rank of 2<sup>nd</sup> Class Petty Officer (E-5).

23  
24  
25  
26  
27  
28