



**James F. Walsh**  
Senior Counsel

101 Ash Street  
HQ13D  
San Diego, CA 92101-3017

Tel: 619. 699. 5022  
Fax: 619. 699. 5027  
jwalsh@sempra.com

January 28, 2005

To All Parties of Record in A.04-02-026

Re: SONGS 2 & 3 Steam Generator Replacement Application; SDG&E Errata

Please find enclosed San Diego Gas & Electric Company's errata to the direct testimony of SDG&E's Mr. Richard Sheaffer. Copies of this errata are being electronically delivered to all parties of record and ALJ O'Donnell today. Hard copies will be mailed today.

Sincerely,

A handwritten signature in cursive script that reads "James Walsh". The signature is written in black ink and is positioned above the printed name.

James F. Walsh  
Attorney for  
San Diego Gas & Electric Company

Enclosures

JFW:cj


Application of Southern California Edison )  
Company (U 338-E) for Authorization: )  
(1) to replace San Onofre Nuclear )  
(SONGS 2 & 3) steam generators; (2) )  
establish ratemaking for cost recovery; and )  
(3) address other related steam generator )  
replacement issues. )  
\_\_\_\_\_ )

Application No. 04-02-026  
Exhibit No. \_\_ (SDG&E-\_\_)  
Witness: Richard Sheaffer

**ERRATA TO**  
**PREPARED DIRECT TESTIMONY**  
**OF RICHARD SHEAFFER**  
**ON BEHALF OF SAN DIEGO GAS & ELECTRIC COMPANY**


**BEFORE THE PUBLIC UTILITIES COMMISSION**  
**OF THE STATE OF CALIFORNIA**

**January 28, 2005**



**Figure 1-1: Incorrect Otay Mesa Interconnection Represented in SCE Filing Cases**

1  
2



**Figure 1-2: Correct Otay Mesa Interconnection Cases**

3

1                   **C. SCE’s Modeling of the Palomar Generation Interconnection Results in**  
2                   **Erroneous Conclusions**

3                   Another critical assumption made in SCE’s Transmission Alternatives And  
4 Associated Costs Study involved its modeling of the Palomar generation and associated  
5 interconnection. SCE used these incorrect assumptions in the study cases it utilized in  
6 Exhibit SCE-5. In the SCE “SONGS On” case, the Palomar generation was not shown as  
7 running. In the other four SCE cases, the ~~351~~<sup>521</sup> MW (and corresponding reactive flow up  
8 to 306 MVAR) of Palomar generation was directly tied into the Escondido 230 bus as  
9 one large unit. Such a simplifying representation was undoubtedly easier for modeling  
10 purposes, but incorrectly placed the Palomar generation output onto SDG&E’s existing  
11 230/138/69 kV system. As a result, this model results in unrealistic power flows and  
12 other system stresses within SDG&E’s system that would lead to substantially erroneous  
13 conclusions.

14                   The correct representation for the Palomar generation and associated  
15 interconnection is to accurately represent the Palomar power plant as three distinct units  
16 (two Combustion Turbines or “CTs” and one Steam unit). Further, the units are to be  
17 connected to a Palomar 230 kV bus that has the existing Escondido – Sycamore 230 kV  
18 line looped into it (presently planned by October 2005), shown below in Figure 2-1.<sup>3</sup>  
19 Additionally, the nearby 138 kV system needs to be modeled as being reinforced as well  
20 for reliability reasons in preventing overloads (presently planned by June 2006), as  
21 shown below in Figure 2-2. The following diagram represents these planned system  
22 additions, including a new transformer at Sycamore Canyon Substation, which are not

---

<sup>3</sup> Direct Testimony of David M. Korinek in Order Instituting Rulemaking to establish Policies and Cost Recovery Mechanisms for Generation Procurement and Renewable Resource Development, R.01-10-024, dated October 7, 2003.




Figure 2-2

**D. SCE Incorrectly Adds Excessive Load to SDG&E's Model**

For the year 2010, SDG&E's projected load and loss is ~~5024~~<sup>4920</sup> MW, as in the Long

Term Resource Plan filed with the CPUC. SCE contends in its Exhibit SCE-5 is that

"San Diego Gas & Electric Company's (SDG&E) Transmission Planning department

provided information that SCE used to model SDG&E's transmission system in future

year 2010". ~~Not only does this~~ <sup>This does</sup> not make reference to the fact that ~~this~~ <sup>such</sup> information was

~~obtained for purported joint study purposes, but also infers that SDG&E agrees with the~~ <sup>At the time the joint study was being</sup>

~~prepared, SDG&E's 2003 load forecast for the year 2010 was 5031 MW (load~~ <sup>prepared, SDG&E's 2003 load forecast for the year 2010 was 5031 MW (load</sup>

~~way that SCE used this data, which SDG&E does not. SCE's Transmission Alternatives~~ <sup>way that SCE used this data, which SDG&E does not. SCE's Transmission Alternatives</sup>

~~plus loss). Since the time SDG&E provided that number to SCE for joint~~ <sup>plus loss). Since the time SDG&E provided that number to SCE for joint</sup>

~~And Associated Costs Study incorrectly added losses again to this load number, thus~~ <sup>And Associated Costs Study incorrectly added losses again to this load number, thus</sup>

~~study purposes, the SDG&E load forecast (as reflected in the 2004 resource~~ <sup>study purposes, the SDG&E load forecast (as reflected in the 2004 resource</sup>

~~double counting the losses and representing SDG&E's load and loss quantity to be 5044~~ <sup>double counting the losses and representing SDG&E's load and loss quantity to be 5044</sup>

~~plan) has been revised downward by 111 MW to a level of 4920 MW. Absent~~ <sup>plan) has been revised downward by 111 MW to a level of 4920 MW. Absent</sup>

~~111 MW, this additional 111 MW, which essentially acts as 111 MW of load above and~~ <sup>111 MW, this additional 111 MW, which essentially acts as 111 MW of load above and</sup>

~~that update, SCE's studies show an excess load of 111 MW. This additional~~ <sup>that update, SCE's studies show an excess load of 111 MW. This additional</sup>

~~beyond what is expected in SDG&E's area, unrealistically stresses SDG&E's system.~~ <sup>beyond what is expected in SDG&E's area, unrealistically stresses SDG&E's system.</sup>

~~111 MW, which essentially acts as 111 MW of load above and beyond what is~~ <sup>111 MW, which essentially acts as 111 MW of load above and beyond what is</sup>

~~expected in SDG&E's area, unrealistically stresses SDG&E's system,~~ <sup>expected in SDG&E's area, unrealistically stresses SDG&E's system,</sup>

1 mistakenly giving the appearance that certain mitigations are needed, when in fact those  
2 mitigations are not needed. Therefore, the conclusions pertaining to this aspect of SCE's  
3 study are ~~not accurate or credible~~ outdated and would be different if the studies were performed  
4 using that updated load forecast.

5 **E. SCE's Inaccurate Modeling of Voltage Control Devices Results in Excess**  
6 **Need for Voltage Support**

7 All five cases used in SCE's Transmission Alternatives And Associated Costs  
8 Study modeled Heavy Summer peak load and high Southwest Powerlink ("SWPL") flow.  
9 Based on those conditions, SCE incorrectly modeled many voltage control devices as  
10 being on-line when in fact they should have been off. These types of devices are needed  
11 for light loading conditions, when the MVAR "charging" of long transmission lines  
12 causes voltage to rise excessively. Conversely, for heavy loading conditions (such as  
13 those modeled in SCE's and SDG&E's studies), these types of devices need to be  
14 removed to avoid degrading the voltage. Specifically, these included:

- 14 • two 114 MVAR line reactors on the Hassayampa (Palo  
15 Verde area) – North Gila 500 kV Line;
- 16 • one 114 MVAR line reactor at the Imperial Valley side of  
17 the North Gila – Imperial Valley 500 kV Line; and
- 18 • one of the Miguel 45 MVAR tertiary shunt reactors.  
19

20  
21  
22 These reactors are used to regulate the voltage at these substations, and the  
23 simulation of these reactors on-line, when in fact they should be off, artificially creates  
24 the apparent, erroneous "need" for additional Static VAR Compensators ("SVCs"). The  
25 same type of erroneous assumptions also occurred in regard to the line reactors at both  
26 ends of the existing Palo Verde – Devers 500 kV Line. Separate from other data errors  
27 pointed out by SDG&E, the reactor errors described here alone account for about 640  
28 MVAR of excessive need for SVCs seen in SCE's transmission study.

1 Units 2 & 3, there exist 130 MVAR that flow from SDG&E to SCE at the SONGS  
2 interconnection.

3 All of these case scenarios undertaken by SCE and SDG&E indicate that  
4 SDG&E's system is providing voltage support to the SCE system. Thus, it is SCE that  
5 benefits from voltage support from SDG&E, with or without the presence of the SONGS  
6 units, not the other way around as SCE incorrectly would lead us to believe.

7 These conclusions are confirmed by examining historical real-time data  
8 recordings as opposed to study results of future scenarios. For example, both SONGS  
9 Units 2 and 3 were recently off-line in the November 19 to November 23, 2004 period.  
10 At that time, Unit 3 was down for refueling and other repairs, when Unit 2 tripped off-  
11 line. Real-time data of the MVAR flow from SDG&E's five 230 kV lines to the SONGS  
12 230 kV bus during that period indicate that an average of 73 MVAR were flowing from  
13 SDG&E's system to SCE's system, again illustrating the voltage support that SDG&E  
14 was providing to SCE (via the SONGS 230 kV bus) during that period. In yet another  
15 example, the hourly recorded data was examined for the <sup>last seven months</sup> ~~second half~~ of the previous year,  
16 2003. In that data, I see an average of 77.7 MVAR flowing from the SDG&E system to  
17 the SONGS 230 kV bus (the SONGS interconnection with SCE). At the same time, the  
18 recorded data shows that the average MVAR output of Unit 2 was 16.1 MVAR and the  
19 MVAR output of Unit 3 was 16.7 MVAR, a total of 32.8 MVAR. Therefore, I conclude  
20 that on average for that data period, 100% of the MVAR output of the SONGS units  
21 flowed to the SCE system (to support the SCE system voltage). While on average  
22 SDG&E received none of those SONGS-produced MVARs to support its own system  
23 voltage, the SDG&E system actually sent an additional 44.9 MVARs of voltage support