

Application No.: A.06-04-_____
Exhibit No.: SDG&E-4
Witness: William V. Torre

In the Matter of San Diego Gas & Electric Company's
Application for Authorization to (1) to Participate in
the Steam Generator Replacement Project As A Co-
Owner of San Onofre Nuclear Generating Station Unit
Nos. 2 & 3 (SONGS 2 & 3) ; (2) Establish Ratemaking
For Cost Recovery; and (3) Address Other Related
Steam Generator Replacement Issues

(U 902-E)

Application No. 06-04-____

PREPARED DIRECT TESTIMONY

OF

WILLIAM V. TORRE

BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF CALIFORNIA

APRIL 14, 2006

TABLE OF CONTENTS

I. PURPOSE OF TESTIMONY..... 1

II. DEVELOPMENT OF COST ESTIMATES FOR TRANSMISSION AND SUBSTATION
COMPONENTS 2

III. DESCRIPTION OF COST ESTIMATES 4

IV. QUALIFICATIONS OF WITNESS..... 6

1 **PREPARED DIRECT TESTIMONY**

2 **OF**

3 **WILLIAM V. TORRE**

4
5 **I. PURPOSE OF TESTIMONY**

6 My testimony describes the cost estimates developed by San Diego Gas & Electric
7 Company (“SDG&E” or “the Company”) for transmission and substation facilities for two
8 potential sources of replacement generating capacity that could be used by SDG&E to replace its
9 ownership share in the San Onofre Nuclear Generating Station (“SONGS”). I will refer to this
10 SDG&E ownership share as “SONGS-Share.” The purpose of my testimony is to describe the
11 cost estimates for transmission system reinforcements (“reinforcements”) that would need to be
12 made if the Company were to replace its SONGS-Share with either of the two replacement
13 generating sources analyzed.

14 R.J. Rudden Associates, a unit of Black & Veatch Corporation (“B&V”) conducted
15 transmission planning studies at the direction of SDG&E witness Mr. Richard Sheaffer. Based
16 on these studies Mr. Richard Sheaffer determined the physical changes to the Company’s
17 transmission system that would be required to accommodate each of the SONGS-Share
18 replacement alternatives considered by SDG&E witness Mr. Michael Schneider. Mr. Richard
19 Sheaffer then provided descriptions of these system reinforcements to me for the purposes of
20 estimating the costs of the modifications. I provided these cost estimates to Mr. Schneider for
21 inclusion in his comparative generation economics analysis.
22

1 **II. DEVELOPMENT OF COST ESTIMATES FOR TRANSMISSION AND**
2 **SUBSTATION COMPONENTS**

3 The cost estimates, for upgrades to existing facilities, developed for this study are
4 considered to be budget class cost estimates. Budget class cost estimates consider the cost of
5 major construction activities including labor, materials, engineering, land procurement, and
6 licensing activities, as well as all applicable overhead costs that could be incurred by SDG&E.

7 To provide a budget class estimate for the transmission related work, SDG&E will
8 typically first perform document research. This will include researching the pole/tower sizes,
9 existing wire tensions, clearances, etc. to estimate the impact of completing the required work.
10 Any tools available such as Geographic Information System (“GIS”) will be used to further
11 assess the project impacts (provides pole locations, residential areas, types of environment, open
12 spaces, etc). A field review of the line of known routes is performed providing information such
13 as regarding access roads, obstructions installed on Right of Way (“ROW”), deteriorated pole
14 replacements necessary, etc.

15 To provide a budget class estimate for substation related work, SDG&E will perform
16 document research and derive a detailed scope of engineering, procurement, and construction
17 based on the basic project description. In addition to using an extensive up-to-date data base of
18 work scope items, vendors and subject matter experts may be consulted to ensure that large cost
19 items (major equipment and site development) are accurately estimated.

20 Cost estimates include the latest overhead costs (administrative & general, local
21 engineering), labor rates, material costs, land acquisition, and contingency costs. Contingency
22 percentages and difficulty factors added are typically based on the designers/engineers judgment
23 of potential unknowns that could surface to increase the project total costs. A contingency level
24 of 30% was used for upgrades of both existing transmission and substation components for the

1 cost estimates provided in this study. A contingency level of 50% was used for new facilities
2 associated with Scenario 2 due to the higher level of uncertainty of project scope.

3 Cost estimates were developed for two “Replacement Scenarios” (Replacement Scenario
4 1 and Replacement Scenario 2). The two Replacement Scenarios are described below:

- 5
6 • *Replacement Scenario 1* models the Company’s transmission plans under the
7 assumption that its SONGS-Share is replaced by a 541 MW Combined Cycle
8 Combustion Turbine (“CCCT”) power plant located at the present Encina site.
9 Cost estimates were developed for the following components for this scenario:

10
11 1. Acceleration of the reconductoring of the Escondido to Felicita 69 kV
12 line to 2015 (identified in the Reference Case as being otherwise
13 needed by 2022), an advancement of approximately seven years. The
14 project would increase the rating of the 69 kV line from 97.5 MVA to
15 137 MVA using a single 1033 kCMIL aluminum conductor steel
16 reinforced (“ACSR”) conductor.

17
18 2. Acceleration of the reconductoring of the Felicita to Ash Tap 69 kV
19 line to 2015 (identified in the Reference Case as being otherwise
20 needed by 2022), an advancement of approximately seven years. The
21 project would increase the rating of the 69 kV line from 97.5 MVA to
22 137 MVA using a single 1033 kCMIL ACSR conductor.

- 23
24 • *Replacement Scenario 2* models SDG&E’s transmission plans under the
25 assumption that the Company substitutes its SONGS-Share from a geothermal
26 power plant that is interconnected to SDG&E’s transmission system at the
27 Imperial Valley Substation. Cost estimates were developed for the following
28 components for this scenario:

29
30 1. Addition of a third 500 kV to 230 kV transformer (1120 MVA) at the
31 Imperial Valley Substation in 2010.

32
33 2. Addition of a third 230 kV to 69 kV transformer (224 MVA) at the
34 Sycamore Canyon Substation in 2015.

35
36 3. Acceleration of the reconductoring of the Felicita to Ash Tap 69 kV
37 line (6.2 miles) to 2015 (identified in the Reference Case as being
38 otherwise needed by 2022), an advancement of approximately seven
39 years. The project would increase the rating of the 69 kV line from
40 97.5 MVA to 137 MVA using a single 1033 kcmil ACSR conductor.
41 Reconductoring of two 69 kV lines, Sycamore to Pomerado 69 kV
42 double circuit line (2 miles), and San Luis Rey to Melrose Tap 69 kV
43 line (4.2 miles) to increase the rating of each circuit to 204 MVA.
44

- 1 4. A double-circuit 230 kV overhead transmission line, 20 miles long,
2 from the step-up substation at the hypothetical geothermal plant to the
3 Imperial Valley 230 kV Substation. Both circuits will use at bundled
4 1033 kcmil ACSR conductor per phase.
5
- 6 5. At the step-up substation located at the geothermal power plant site,
7 four breaker-and-a-half bays are to be provided for four leads from the
8 230 kV side of four 13.8/230 kV step-up transformers, and to
9 terminate two 230 kV lines from Imperial Valley, and two spare
10 positions for future connections. A total of ten 230 kV circuit breaker,
11 plus associated buswork and controls are included. Generator circuit
12 breakers and step-up transformers are not included.
13
- 14 6. At Imperial Valley, an extension of the 230 kV main bus, installation
15 of two 230 kV bays to include two line positions and circuit breakers
16 which will accommodate terminating two 230 kV lines from the
17 hypothetical geothermal plant. This will also include two tie positions
18 with breakers, two transformer bank positions without circuit breakers
19 and associated controls.
20

21 In both of the two Replacement Scenarios, Mr. Michael Schneider specified the general
22 location of the replacement generation. Mr. Richard Sheaffer through his planning studies
23 provided the determination of the transmission reinforcements required to reliably support the
24 replacement generation on the transmission system.
25

26 **III. DESCRIPTION OF COST ESTIMATES**

27 The cost estimates for each of these scenarios are summarized in the tables shown below.
28 All costs were estimated in 2006 dollars for use by Mr. Schneider in his economic analysis and
29 escalated by him to the appropriate year. The following Table 1, summarizes cost estimates for
30 Scenario 1 transmission and substation components.

Table 1

Project Name: Scenario 1							
Estimate: COST SHOWN IN 2006 DOLLARS X 1,000							
Year	Prior Years	2006	2007	2008	2009	2010	Total
Transmission	0	8,147	0	0	0	0	8,147
Substation	0	886	0	0	0	0	886
Total w/o AFUDC	0	9,033	0	0	0	0	9,033
AFUDC	0	858	0	0	0	0	858
Total w/ AFUDC	0	9,891	0	0	0	0	\$9,891

The following Table 2 provides a summary of the cost estimates for Scenario 2, for the transmission and substation components.

Table 2

Project Name: Scenario 2							
Estimate: COST SHOWN IN 2006 DOLLARS X 1,000							
Year	Prior Years	2006	2007	2008	2009	2010	Total
Transmission	0	68,839	0	0	0	0	68,839
Substation	0	75,885	0	0	0	0	75,885
Total w/o AFUDC	0	144,724	0	0	0	0	144,724
AFUDC	0	13,749	0	0	0	0	13,749
Total w/ AFUDC	0	158,473	0	0	0	0	\$158,473

A breakdown of the costs of each transmission component is provided in Exhibit 1.

1 **IV. QUALIFICATIONS OF WITNESS**

2 My name is William V. Torre. My business address is San Diego Gas & Electric
3 Company, 8316 Century Park Court, CP52A, San Diego, CA 92123. I am presently employed
4 by San Diego Gas & Electric Company (“SDG&E”) as Manager of the Electric Transmission
5 Engineering and Design Section. I have been the manager of Transmission Engineering and
6 Design for approximately 5 years.

7 I graduated with a Bachelor of Science degree in Electrical Engineering (“BSEE”) from
8 The University of Missouri - Rolla in 1976. I later received a Master of Science degree in
9 Electrical Engineering (“MSEE”) from the California Polytechnic State University – San Luis
10 Obispo in 1979. I am also a registered Professional Engineer (in the Electrical Branch) in the
11 State of California (No. 10358).

12 With respect to my professional experience, I worked for Pacific Gas and Electric
13 Company (“PG&E”) during the period from 1976 to 1979. I have worked for SDG&E for
14 approximately 22 years.

15 I have held a number of positions throughout my career involving electric utilities, the
16 majority of which have involved electric transmission planning, construction and engineering.
17 Such positions have involved modeling of the transmission grid for both California and the
18 interconnected system of the Western Systems Coordinating Council (“WSCC”). I have also
19 served as a representative on the WSCC Technical Studies Subcommittee, Pacific and Southwest
20 Transfer Subcommittee, and Rating Methods Task Force. WSCC is now known as the Western
21 Electricity Coordinating Council (“WECC”). I also have written several technical papers for the
22 IEEE and served on several working groups.

23 I have previously testified before this Commission.

24 This concludes my prepared direct testimony.

Exhibit 1

Transmission and Substation Cost Estimate Breakdown

EXHIBIT 1
SDG&E Cost Estimates*

*Estimates are in 2006 dollars and include AFUDC.

Project Description	Tie Line Number	ISD	Unescalated Estimate (\$ 000)
Transmission Reinforcements Associated w/ Scenario 1:			
Escondido-Felicita Reconductor to 137 MVA	TL 679	2015	\$ 4,033
Felicita-Ash Tap Reconductor to 137 MVA	TL 681	2015	\$ 5,859
Total Unescalated Cost of Scenario 1 Transmission Reinforcements:			\$ 9,891
Transmission Reinforcements Associated w/ Scenario 2:			
Imperial Valley Sub. 3rd 500/230kV Bank	-	2010	\$ 36,341
Sycamore Canyon Sub. 3rd 230/69kV Bank	-	2015	\$ 11,739
Felicita-Ash Tap Reconductor to 137 MVA	TL 681	2015	\$ 5,859
San Luis Rey-Melrose Tap Reconductor to 204 MVA	TL 680	2022	\$ 3,410
Sycamore Canyon-Pomerado Reconductor to 204 MVA	TL 6915 and 6924	2015	\$ 4,125
New Dbl. Ckt. 230 kV Transmission Line Geothermal to IV		2010	\$ 62,465
New 230 kV Substation at Geothermal		2010	\$ 23,868
I V Upgrade to Interconnect Geothermal 230 kV Lines		2010	\$ 10,666
Total Unescalated Cost of Scenario 2 Transmission Reinforcements:			\$ 158,473